



Sewage Collection and Wastewater Treatment Report for the Fiscal Year July 2013 – June 2014

This is the fifteenth annual Sewage Collection and Wastewater Treatment Report for the City of Burlington, NC.

On July 21, 1999, North Carolina Governor James Hunt signed a law that placed new reporting requirements on the owners or operators of wastewater treatment and wastewater collection facilities in North Carolina. Part of this legislation was a requirement to provide the users or customers of the system with an annual report of the past year's performance that includes a summary of wastewater spills.

The purpose of these reports is to provide an understandable and informative description of the wastewater treatment facilities and collection system, describe the regulations with which these facilities must comply, and promote a general awareness of these facilities and their role in protecting the environment.

INTRODUCTION

The City of Burlington operates two wastewater treatment facilities and a sewage collection system that collects and transports the sewage to each of these two locations. The names and permit information for these facilities are listed below as well as those professionals designated by the State of North Carolina as Operators in Responsible Charge (ORC)

East Burlington Wastewater Treatment Plant

Quarry Road, Haw River, NC
Phone (336) 578-0515
NPDES Permit # - NC0023868
Operator in Responsible Charge (ORC) – Darrin Allred

Sewage Collection System

1103 S. Mebane Street, Burlington, NC
Phone (336) 222-5140
Collection System Permit # - WQCS00008
Operator in Responsible Charge (ORC) – Donnie West

South Burlington Wastewater Treatment Plant

Boywood Road, Graham, NC
Phone (336) 227-6261
NPDES Permit # - NC0023876
Operator in Responsible Charge (ORC) – Rick Asher

This report is being provided to meet the requirements of North Carolina law (HB 1160). Copies will be available at the East Burlington Wastewater Treatment Plant, the South Burlington Wastewater Treatment Plant, the Water and Sewer Pipe Maintenance facility, the Municipal office building (City Hall) at 425 Lexington Avenue, the May Memorial Public Library, the Public Works building at 234 E Summit Avenue, the Water Resources Office at 1302 Belmont St. and published on the City of Burlington website – www.ci.burlington.nc.us/.

Customers will be notified of the availability of this report by ads in the Burlington Times News.

THE IMPORTANCE OF WASTEWATER TREATMENT

Every living organism interacts with its environment. Pollution is the addition of impurities to the environment. For centuries humans put their sewage into streams, lakes, or oceans. This pollution did not cause significant environmental impact because nature could eliminate it faster than it would accumulate. However, as the human population increased, natural decomposition could no longer keep up with the wastes that were generated. ***The purpose of a wastewater treatment plant is to facilitate the natural decomposition of sewage so that the water released back to the***

environment – typically into a stream or river – will have minimal or no negative impact on the environment. The City of Burlington owns and operates two wastewater treatment facilities. The East Burlington wastewater treatment facility discharges treated water into the Haw River near the NC Highway 70 bypass near the town of Haw River. The South Burlington facility discharges into the Big Alamance Creek near Boywood Road in Swepsonville. This treatment process ensures that water is constantly being recycled.

NPDES PERMIT

The treatment of sewage and its return to the environment can be a delicate and complex balancing act. State agencies assure that stringent standards are met before the treated water can be released into a receiving stream. These standards are summarized in a National Pollutant Discharge Elimination System (NPDES) permit. Each facility, whether public or private, that releases treated wastewater into any surface water – a stream for example – must apply for and possess one of these permits. These permits regulate the type and amounts of pollutants that a facility can discharge. The discharge limits in these permits are based on a particular stream's ability to withstand the addition of pollutants without having a negative impact on the stream's water quality. These permits are different from one wastewater plant to another and even from one season to another. To protect the stream, a facility's NPDES permit assumes that the stream is ALWAYS flowing at its lowest flow. This is called the "7 Q 10" flow. It is meant to represent the lowest flow that the stream will experience in 7 consecutive days once every 10 years. Even when a stream or river is experiencing a high flow due to heavy rain, a wastewater plant must continue to discharge as if the stream were experiencing an unusually low flow. These strict standards provide wastewater plants with a margin of safety when it comes to protecting the environment.

WHERE DOES IT ALL END UP?

Burlington is home to a number of mills and manufacturing plants. These plants use large amounts of water every day. Once used, this water is discharged into the sewer system. Wastewater treatment facilities are primarily designed to treat domestic waste – waste that comes from houses – and sometimes have difficulty treating industrial waste. The various pollutants from many different sources often makes the NPDES permit regulations more difficult to meet. It is a misconception that when something is flushed "down the drain", it is gone, never to be seen or worried about again. People who use the sewer system should be aware of the other end of the drain. When something goes in their end, it will come out - and must be treated - at the other end. When wastewater arrives at the treatment facility, it must go through the entire treatment process. Anything and everything that arrives at the plant must be treated – and the treatment facility must still meet the NPDES permit requirements. This makes the operation of a wastewater plant vulnerable to chemicals or pollutants that might upset the biological treatment process. In order to help prevent unwanted pollutants from entering the sewage treatment process, the City of Burlington laboratory personnel monitor the industrial discharges. Industries that discharge into the Burlington sewer system are inspected and must comply with discharge permits of their own to help protect the sewer collection system, the treatment facility, employees of the City's Water Resources Department, and the environment. In many instances, industries are required to provide treatment of their wastewater before discharging it into the city sewer system. This is often referred to as 'pretreatment' or 'industrial pretreatment'.

COLLECTION SYSTEM OVERVIEW

Burlington's wastewater collection system consists of approximately 20,600 connections serving homes, businesses and industry¹, 428 miles of gravity sewer line, 9,695 manholes², 4 sewer lift stations and approximately 10,718 feet of pressurized force main that is active and maintained by the city. Every day an estimated 11.8 million gallons³ of sewage is transported from our homes and businesses through this collection system to the East Burlington and South Burlington wastewater treatment facilities. The collection system has both gravity lines and force mains. Sewage discharged in neighborhoods flows by gravity into the collection system. As more and more sewage is collected from different service areas, the size of the sewer lines must increase to handle the larger volumes of wastewater. Eventually, these gravity lines reach low points in the collection system where the sewage must be pumped. The City of Burlington currently utilizes four lift stations with a maximum capacity of about 4 million gallons per day and an average flow of about 500,000 gallons per day in 2013-14⁴. These lift stations pump sewage up and over ridges where the sewage can flow by gravity the remainder of the distance to the treatment facilities. The City of Burlington has an ongoing program to clean and monitor the collection system. High-pressure washing, chemical treatment for root growth, a Fats, Oils and Grease (FOG) program, and closed circuit television monitoring program are a few of the tools we use to maintain your collection system and prevent sewer overflows. Last year the City of Burlington sewer collection system transported more than 4,337,000,000 gallons (4.337 Billion Gallons⁵) of wastewater (see Table 1). During that same period, the City experienced 9 reportable sewer overflows resulting in a loss of an estimated 3,630,000 gallons of sewage. The single largest overflow of 3,500,000 gallons occurred on Monday, January 28, 2014 when the main force main at the East Burlington WWTP ruptured. The nature, size and weather conditions prevented crews from stopping this overflow immediately. This overflow occurred over the course of 2 days until appropriately-sized equipment could be mobilized to the sight and put into operation. A summary of all the sanitary sewer overflows can be found in Table 3 at the end of this report. This report includes a list of all reportable sanitary sewer overflows between July 1, 2013 and June 30, 2014 in which untreated sewage was released. A reportable instance is one in which untreated sewage enters a stream or river or enters a ditch or waterway that leads to a stream or river, OR any spill that was greater than 1,000 gallons - regardless of whether or not it reaches a stream.

High flows at the treatment plants are sometimes caused by heavy rains or long periods of rainy weather. These high flows are caused by water infiltrating the sewer system. The City is

¹ Customer Service

² Donnie West – Pipe Maintenance Assistant Superintendent

³ Sum of combined DMR flows for fiscal year

⁴ Plants Maintenance Superintendent Report

⁵ * to help comprehend how large one Billion is: 1 billion seconds is 32 years, 1 billion inches is 15,800 miles.

engaged in a continual program to reduce the amount of overflows that result from the infiltration of rainwater. The City is also paying closer attention to those areas where falling debris (such as a falling tree or tree limb) could damage above-ground sewer lines and result in a sewage release.

SUMMARY

In fiscal year 2013-14 the City of Burlington spent approximately \$1.4 million to construct, repair and maintain the city sewer collection lines and approximately \$4.1 million to operate and maintain the wastewater treatment facilities and equipment. In addition to the recurring annual expenses, the wastewater treatment plants recently completed a number of upgrades that began in 2012. These upgrades included enhancements to the biological treatment processes at both plants (\$16.6 Million), New Filters at the South Burlington Plant (\$5.6 Million) and a New 30" Force Main at the East Burlington Plant (\$1.1 Million). These modifications will help the facilities comply with new nutrient regulations to help protect water quality in Jordan Lake that are scheduled to go into effect in

2019. The Water Resources Department is proud of the performance of our collection system and treatment plants for the past year. Despite the dedicated efforts of our wastewater treatment plant staff, it is often difficult to avoid violations of the NPDES permit. Table 2 at the end of this report contains a list of the NPDES permit violations for this past reporting year. Violations or spills are often a result of conditions that are beyond the reasonable control of the operator. Weather and vandalism are two examples that may cause a violation. Our ultimate goal is to have no spills or permit violations. We want to provide the best possible service to our customers and continue to be responsible stewards of our environment and of our financial resources. We also want the public to understand the importance of protecting our precious water resources. We believe providing information is one of the most effective tools to ensure the support needed to meet our goals to protect our environment – now and into the future.

For more information, please contact the Department of Water Resources at (336) 222-5133.

Table 1 – Monthly Discharge Volumes

City of Burlington Summary of Wastewater Flows* July 1, 2013 - June 30, 2014 all flows are expressed as million gallons (MG)			
Month / Year	South Burlington	East Burlington	Combined Total
Jul-13	252.0	151.7	403.7
Aug-13	212.3	144.2	356.5
Sep-13	174.1	120.2	294.3
Oct-13	167.9	124.8	292.7
Nov-13	161.2	137.3	298.5
Dec-13	214.7	174.0	388.7
Jan-14	241.2	175.5	416.7
Feb-14	218.2	148.2	366.4
Mar-14	285.6	165.1	450.7
Apr-14	252.1*	147.7	399.8
May-14	229.3	141.6	370.9
Jun-14	176.1	122.0	298.1
Total (MG)	2,584.7	1,752.3	4,337.0
Average Month (MG)	215.4	146.0	361.4
Average Day (MG)	7.081	4.801	11.882
This table is based on a 365 day fiscal year beginning July 1, 2013 and ending June 30, 2014 An "*" indicates that a permit violation occurred during this month. See table 2.			

Table 2 – NPDES Permit Violations

East Burlington WWTP - Summary of Violations - July 1, 2013 - June 30, 2014			
Month / Year	Violation	Environmental Impact	Number of Violations
No NPDES Violations during the reporting period			
South Burlington WWTP - Summary of Violations - July 1, 2013 - June 30, 2014			
Month / Year	Violation	Environmental Impact	Number of Violations
April 2014	Ammonia – exceeded monthly average	None observed or reported	1
April 2014	Ammonia – exceeded weekly average	None observed or reported	1
April 2014	BOD – exceeded monthly average	None observed or reported	1
April 2014	BOD – exceeded weekly average	None observed or reported	1

- All four (4) of the violations listed in the table above were the result of an electrical failure at the plant that took six days to repair. During that period of time, the treatment process was impacted to the point that these violation occurred.

Table 3 – List of Reportable Sanitary Sewer Overflows

Date

Date	Volume ⁶	Location of Overflow	Caused by	Environmental Impact	Action Taken
7/4/13	71,250	Mayfair Mill Outfall	Falling Tree	None observed or reported	Plugged Line, rerouted flow, repaired damage
8/13/13	100	530 Beaumont Avenue	Grease	None observed or reported	Jetted Line, Limed Area
11/27/13	6,913	Behind 510 James Street	Grease	None observed or reported	Jetted Line, Cleaned Debris, Limed Area
12/26/13	300	1507 Stout Street	Debris ⁷	None observed or reported	Jetted Line, Limed Area
1/11/14	50,400	1144 Graham Hopedale Road	Excess Flow ⁸	None observed or reported	No Action Taken
1/20/14	1,000	1903 Lewis Avenue	Grease	None observed or reported	Jetted Line, Cleaned Debris, Flushed Area
1/26/14	200	251 Rolling Road	Debris	None observed or reported	Jetted Line, Cleaned Debris, Flushed Area
1/28/14 ⁹	3,500,000	4 Manholes on 42" Haw River Outfall	Force Main Fail	None observed or reported	Bypass Installed and Force Main replaced
2/18/14	250	2708 Westchester Drive	Roots	None observed or reported	Roots were cut out and flow was restored

Total Estimated Overflow for fiscal year 2013 – 14 3,630,413 gallons

⁶ This amount reflects the volume of untreated sewage that reached a surface water

⁷ Debris consisted mainly of baby wipes that had been placed into the sewer

⁸ 2.25" of local rainfall within 24 hours with more than 1" falling in a period less than 1 hour

⁹ This overflow was a highly publicized event. It occurred during an abnormally cold period in January and, consequently, no environmental impact was ever observed or reported anywhere along the Haw River from Burlington to Pittsboro.

CERTIFICATION

2013 – 14 Annual Report
of the
Collection System and Wastewater Treatment Facilities
for the
City of Burlington, NC
August 28, 2014

East Burlington Wastewater Treatment Plant
Quarry Road, Haw River, NC
Phone (336) 578-0515
NPDES Permit # - NC0023868
Operator in Responsible Charge (ORC) – Darrin Allred

Sewage Collection System
1103 S. Mebane Street, Burlington, NC
Phone (336) 222-5140
Collection System Permit # - WQCS00008
Operator in Responsible Charge (ORC) – Donnie West

South Burlington Wastewater Treatment Plant
Boywood Road, Graham, NC
Phone (336) 227-6261
NPDES Permit # - NC0023876
Operator in Responsible Charge (ORC) – Rick Asher

I certify, under penalty of law, that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users have been notified of its availability.

Robert Patterson
Water Resources Director
City of Burlington

Date

City of Burlington
Water Resources Department
Advertisement

Notice of Wastewater Treatment and Collection System Report Availability

The City of Burlington Water Resources Department has completed the annual report of Wastewater Treatment and collection System performance for the fiscal year 2013-2014. If you would like to obtain a copy of this report you may pick one up at any of the following locations: The Municipal Building (City Hall) at 425 Lexington Avenue. The May Memorial Public Library, The Public Works Building at 234 E. Summit Avenue, or the Water Resources Office at 1302 Belmont St. This report has also been published on the City of Burlington's website at: www.ci.burlington.nc.us

If you have any questions concerning the availability of this report, please contact personnel in the Water Resources Department by calling (336) 222-5133